



County of San Diego  
Planning & Development Services  
**BUILDING DIVISION**

**ACCESSIBILITY CORRECTION LIST**

Multifamily Housing

**15A**

**Dwelling Units**

PLAN CHECK #:

OWNER ON APPLICATION:

**SCOPING**

1. The adaptability and accessibility requirements of this correction list apply to covered multifamily dwelling units per the scoping provisions of accessibility correction list 1A.

*CBC 1128A.1*

**ACCESSIBLE ROUTES**

2. Dimension minimum 36-inch-wide accessible route within each covered multifamily dwelling unit per the following:
- ☐ Passes through primary entry door
  - ☐ Connects with all additional exterior doors
  - ☐ Connects with required clear floor spaces at kitchen appliances and bathroom fixtures
  - ☐ Provide access to all rooms and spaces within dwelling unit
- Exception:** Accessible routes required only on primary entry level in multistory dwelling units per scoping provisions of accessibility correction list 1A
- Exception:** Accessible route not required from interior of unit into garage if provisions of accessibility correction list 2A are met
- Exception:** Accessible route not required from interior of unit into basement

*CBC 1102A.3, CBC 1130A.1, and CBC 1130A.2*

3. Accessible floors within dwelling units shall be on common level throughout or connected by at least one of the following:
- ☐ Pedestrian ramps per accessibility correction list 4A
  - ☐ Passenger elevators per accessibility correction list 8A
  - ☐ Platform/wheelchair lifts per accessibility correction list 8A
- Exception:** Changes in level up to ¼ inch
- Exception:** Changes in level between ¼ inch and ½ inch with maximum 1:2 slope (50% gradient) per CBC Figure 11A-1C(d)
- Exception:** Landings at doors per item 7

*CBC 1131A.1 and CBC 1131A.2*

**DOORS**

4. Provide dimensions on door/gate schedule indicating all doors and gates comply with the following:
- ☐ Capable of opening minimum 90 degrees
  - ☐ Minimum 32-inch clear width – 34-inch nominal door or 6-foot-wide sliding door acceptable – measured with door at 90-degree angle from its closed position
- Exception:** Minimum 36-inch nominal door required at primary entry and all required exits
- ☐ Minimum 80-inches high
  - ☐ Where pair of doors proposed, at least one door leaf shall provide minimum 32-inch clear width, measured with door at 90-degree angle from its closed position

*CBC 1126A.1 and CBC 1132A.3*

5. Where pocket doors proposed, specify on door schedule bumpers to prevent doors from fully receding.

*CBC 1132A.8*

6. Specify level landing – maximum 1:48 slope (2.1% gradient) in all directions – on each side of each door.

*CBC 1132A.4*

7. Detail any elevation changes at doors complying with the following between interior and exterior floor levels:
- ☐ At exterior landings of impervious construction – e.g., concrete, brick, flatwork – serving primary entry door and required exit doors, maximum ½-inch elevation change complying with CBC Figure 11A-1C(d)
  - ☐ At secondary exterior doors on to decks, patios, or balconies of impervious construction, maximum 1-inch elevation change accomplished with ramp with maximum 1:8 slope (12.5% gradient) per CBC Figure 11A-8K
- Exception:** Maximum 4-inch elevation change with any elevation change greater than ½ inch accomplished by pedestrian ramp per accessibility correction list 4A or built-up platform per CBC Figure 11A-8J
- ☐ At exterior landings of pervious construction – e.g., wood decking with spaces, no elevation change allowed
- Exception:** Maximum ½-inch elevation change per CBC Figure 11A-1C(d) allowed at secondary exit doors

*CBC 1132A.4*

8. Detail door thresholds complying with the following per CBC Figure 11A-8I:

- ☐ Maximum ½-inch vertical between landing and threshold
- Exception:** Maximum ¾-inch vertical acceptable at secondary exterior doors
- ☐ Maximum 1:2 beveled slope (50% gradient) for changes in level between ¼ inch and ½ inch

*CBC 1132A.4.1*

9. Dimension maneuvering clearances complying with the following at each door:

- ☐ Pull side of door:
  - Width: Door width plus minimum 18 inches beyond latch
  - Depth: Minimum 42 inches perpendicular to doorway

**Exception:** Minimum 39 inches perpendicular to doorway acceptable at doors with minimum 34-inch clear opening width
- ☐ Push side of door:
  - Width: Door width
  - Depth: Minimum 42 inches perpendicular to doorway

**Exception:** Minimum 44 inches perpendicular to doorway required on dwelling side of primary entry door and required exit doors

**Exception:** Minimum 39 inches perpendicular to doorway acceptable at doors with minimum 34-inch clear opening width

**Exception:** Maneuvering clearances per accessibility correction list 6A shall apply to sides of dwelling unit doors exposed to common-use spaces

*CBC 1132A.5.2*

**THIS DOCUMENT IS FOR PLAN REVIEW ONLY.  
CORRECTION LIST ITEMS MAY NOT BE REPRODUCED OR COPIED ON PLANS.  
PROVIDE COMPLETE DETAILS, DIMENSIONS, AND NOTES TO SATISFY CORRECTION ITEMS.**

5510 OVERLAND AVE, SUITE 110, SAN DIEGO, CA 92123 • (858) 565-5920 • (888) 336-7553

[HTTP://WWW.SDCPS.ORG](http://www.sdcps.org)

10. Specify on door/gate schedule hand-activated opening hardware, handles, pulls, latches, locks, and other operating devices complying with the following for all doors and gates:
- ☐ Minimum 34 inches and maximum 44 inches above floor
  - ☐ Operable within force limits of item 14
  - ☐ Operable by single effort and without tight grasping, tight pinching, or twisting of the wrist

*CBC 1008.1.9.2 and CBC 1132A.8*

11. Any exit door or gate with locking hardware shall operate per item 10 in direction of egress.

*CBC 1132A.8*

12. Specify lever hardware shall be curved to return within ½ inch of door to prevent catching of clothing during egress.

**Exception:** Group R and U occupancies with occupant load of ten or fewer

*CBC 1132A.8.1*

13. Specify smooth, uninterrupted surface at bottom 10 inches of all doors and gates allowing opening by wheelchair footrest without creating trap or hazardous condition.

**Exception:** Automatic or sliding doors or gates

*CBC 1132A.9*

14. Specify door/gate opening force complying with the following:

- ☐ Maximum 8.5 pounds of force for exterior doors or gates
- ☐ Maximum 5 pounds of force for interior doors or gates

**Exception:** Doors or gates with automatic or power-assist devices may be used to meet maximum force limits

**Exception:** Required fire doors may have minimum opening force allowed by fire jurisdiction, not to exceed 15 pounds of force

*CBC 1132A.6*

15. Specify buzzer, bell, or chime at maximum 48 inches above floor at primary entrance to each covered multifamily dwelling unit.

*CBC 1132A.10*

## KITCHENS

16. Dimension clear floor space complying with the following at each kitchen appliance and fixture:

- ☐ Minimum 30 inches by 48 inches allowing parallel approach to range or cooktop allowing parallel approach
- ☐ Minimum 30 inches by 48 inches allowing forward or parallel approach to sink, oven, dishwasher, refrigerator/freezer, trash compactor, and other appliances
- ☐ Clear floor space aligned with centerline of each appliance or fixture

*CBC 1133A.2*

17. Dimension clear width – measured between cabinets, countertops, or appliances – complying with the following at each kitchen:

- ☐ Minimum 60-inch clear width at U-shaped kitchens with range or cooktop located at base of U
- ☐ Minimum 48-inch clear width for all other kitchen configurations

*CBC 1133A.2.1*

18. Specify base cabinets complying with the following directly beneath sink counter area:

- ☐ Removable to provide clearance for wheelchair
- ☐ Removable without specialized tool or knowledge
- ☐ Finished floor beneath sink counter area extending to rear wall

*CBC 1133A.3*

19. Specify countertops complying with the following:

- ☐ Minimum 30-inch length for sink installation
- ☐ Minimum 30-inch length for work surface
- ☐ Sink and work surface may be single minimum 60-inch length or separate minimum 30-inch lengths

**Exception:** Two minimum 15-inch-wide breadboards may be provided in lieu of 30-inch-long work surface

*CBC 1133A.4*

20. Specify repositionable countertops complying with the following at minimum 5% of covered multifamily dwelling units:

- ☐ Enable repositioning to minimum 28-inch height of sink and work surfaces per item 19
  - ☐ Removable base cabinets beneath sink and work surfaces to provide clearance for wheelchair
  - ☐ Sides of adjacent cabinets and rear wall constructed of durable, nonabsorbent materials
  - ☐ Finished floor beneath sink and work surfaces extending to wall
- Exception:** Stone, cultured stone, and tile countertops may be used without meeting repositioning requirements
- Exception:** Two minimum 15-inch-wide breadboards may be provided in lieu of 30-inch-long work surface

*CBC 1133A.4.1*

21. Specify lower shelving and/or drawer space in kitchen at maximum 48 inches above floor.

*CBC 1133A.4.2*

22. Specify faucet controls complying with the following:

- ☐ Operable with maximum 5 pounds of force
- ☐ Operable with one hand and without tight grasping, pinching, or twisting of wrist
- ☐ Self-closing valves allowed if faucet remains open for minimum 10 seconds

*CBC 1133A.6*

## BATHROOM SCOPING

23. Bathrooms within dwelling units shall be configured to comply with one of the following options:

- ☐ Option 1: All bathrooms comply with the following:
  - o Maneuvering spaces per item 25
  - o Bathtubs per items 26 through 29
  - o Showers per items 30 through 36
  - o Water closets per items 37 through 41
  - o Lavatories, vanities, mirrors, and towel fixtures per items 42 through 49
  - o Accessible route into and through bathroom
  - o Accessible door into bathroom per items 4 through 13
  - o Minimum 18-inch strike-edge clearance on pull side of any door swinging into bathroom
  - o Accessible switches, outlets, and controls per items 51 and 52
  - o Reinforced walls per items 27, 33, and 39 allowing for future installation of grab bars at bathtubs, showers, and toilets
- ☐ Option 2: One bathroom complies with the following:
  - o Maneuvering spaces per item 25
  - o Bathtubs per items 26 through 29
  - o Showers per items 30 through 36
  - o Where both bathtub and shower provided in bathroom, at least one shall be accessible

**Exception:** Where dwelling unit contains two or more bathrooms and accessible bathtub provided in one bathroom and shower provided in second bathroom, at least one shower shall meet provisions of items 30 through 36

- o Water closets per items 37 through 41
- o Lavatories, vanities, mirrors, and towel fixtures per items 42 through 49
- o Where two or more lavatories provided, at least one shall be accessible
- o Accessible route into and through bathroom
- o Accessible door into bathroom per items 4 through 13
- o Minimum 18-inch strike-edge clearance on pull side of any door swinging into bathroom
- o Accessible switches, outlets, and controls per items 51 and 52
- o Reinforced walls per items 27, 33, and 39 allowing for future installation of grab bars at bathtubs, showers, and toilets
- o All additional bathrooms complying with provisions listed above for accessible routes, doors, strike-edge clearance, switches, outlets, controls, and wall reinforcement

*CBC 1134A.2*

24. Powder rooms within dwelling units shall comply with the following:
- ☐ Where powder room is only toilet facility located on accessible level, it shall comply with all provisions per option 2 in item 23
  - ☐ Any other powder rooms shall comply with provisions for accessible routes, doors, strike-edge clearance, switches, outlets, controls, and wall reinforcement per option 2 in item 23
- CBC 1133A.3*

## MANEUVERING SPACE

25. Dimension maneuvering space per the following at each bathroom and powder room designed to comply with items 23 and 24:
- ☐ Allowing wheelchair user to enter, close door, use fixtures, reopen door, and exit
  - ☐ Where door swings into bathroom or powder room, minimum 30-inch by 48-inch maneuvering space required within room and outside door swing
  - ☐ Allowing positioning of wheelchair outside door swing as it closes
  - ☐ Allowing use of all fixtures
  - ☐ May include knee and toe space available beneath fixtures
- CBC 1134A.4*

## BATHTUBS

26. Dimension clear floor space per the following at each accessible bathtub:
- ☐ Minimum 48-inches parallel and 30-inches perpendicular – measured from foot or drain end of bathtub -- at side of bathtub or bathtub/shower combination
  - ☐ No door encroachment unless minimum 30-inch by 48-inch maneuvering space provided within bathroom outside door swing
  - ☐ May use knee and toe space beneath lavatory
  - ☐ No encroachment by toilets or cabinets beneath lavatories
- CBC 1134A.4 and CBC 1134A.5(1)*
27. Detail wall reinforcement complying with the following per CBC Figure 11A-9G(b) at accessible bathtubs for future installation of grab bars:
- ☐ At end walls of bathtub:
    - o Located minimum 32 inches and maximum 38 inches above floor
    - o Extending minimum 24 inches from open edge of bathtub toward side wall
    - o Minimum 6-inch nominal height
  - ☐ At side wall of bathtub:
    - o Located maximum 6 inches above bathtub rim
    - o Extending upward minimum 38 inches above floor
    - o Installed to allow installation of 48-inch-long grab bar with each end maximum 6 inches from each end wall
    - o Minimum 6-inch nominal height
- Exception:** Bathtubs installed without surrounding walls shall include reinforcement for future installation of floor-mounted grab bars
- CBC 1134A.5(2)*
28. Specify bathtub faucet and mechanism controls complying with the following:
- ☐ Operable with maximum 5 pounds of force
  - ☐ Operable with one hand and without tight grasping, pinching, or twisting of wrist
  - ☐ Self-closing valves allowed if faucet remains open for minimum 10 seconds
- Exception:** Shower spray units are not required in bathtubs
- CBC 1134A.5(3) and CBC 1134A.5(4)*
29. Specify any enclosures provided for bathtubs shall comply with the following:
- ☐ Any hinged doors swinging outward
  - ☐ Shatter-resistant materials in doors and panels
  - ☐ Glazing in doors and panels per one of the following:
    - o Minimum 1/8-inch-thick fully tempered glass
    - o Minimum 1/4-inch-thick laminated glass
    - o Shatter-resistant plastic
- CBC 1134A.5(5)*

## SHOWERS

30. Dimension clear maneuvering space per the following at each accessible shower:
- ☐ Minimum 30-inches wide by 48-inches long outside shower
  - ☐ Flush and parallel to control wall
  - ☐ No door encroachment unless minimum 30-inch by 48-inch maneuvering space provided within bathroom outside door swing
- CBC 1134A.4 and CBC 1134A.5.4(3)*
31. Dimension accessible shower stalls to comply with one of the following configurations:
- ☐ Minimum 42-inches wide by 48-inches deep with minimum 36-inch-wide entrance opening
  - ☐ Minimum 60-inches wide by 30-inches deep with minimum 60-inch-wide entrance opening
- Exception:** Water closet may project maximum 12 inches into entrance opening provided minimum 36-inch clear space maintained between water closet and shower wall per CBC Figure 11A-9L
- ☐ Minimum 60-inches wide by 36-inches deep with minimum 36-inch-wide entrance opening when wall installed on opening side
- CBC 1134A.6(1)*
32. Specify accessible shower stall floors complying with the following:
- ☐ Maximum 1:24 slope (4.2% gradient) in all directions
  - ☐ Composed of Carborundum, grit-faced tile, or material providing equivalent slip-resistance
- CBC 1134A.6(2)*
33. Detail wall reinforcement complying with the following per CBC Figure 11A-9G(c) at accessible showers for future installation of grab bars:
- ☐ Continuous in all shower walls
  - ☐ Located minimum 32 inches and maximum 38 inches above floor
  - ☐ Minimum 6-inch nominal height
- Exception:** Showers installed with glass walls shall include reinforcement for future installation of floor-mounted or ceiling-mounted grab bars
- CBC 1134A.6(4)*
34. Specify any shower thresholds shall comply with the following:
- ☐ Maximum 2-inch height with maximum 1:2 beveled slope (50% gradient)
- Exception:** Maximum 1/2-high thresholds may have maximum 1:1 beveled slope (100% gradient)
- CBC 1134A.6(5)*
35. Specify shower faucet and mechanism controls complying with the following:
- ☐ Operable with maximum 5 pounds of force
  - ☐ Operable with one hand and without tight grasping, pinching, or twisting of wrist
  - ☐ Self-closing valves allowed if faucet remains open for minimum 10 seconds
- Exception:** Shower spray units are not required in bathtubs
- CBC 1134.6(6)*
36. Specify any enclosures provided for showers shall comply with the following:
- ☐ Any hinged doors swinging outward
  - ☐ Shatter-resistant materials in doors and panels
  - ☐ Glazing in doors and panels per one of the following:
    - o Minimum 1/8-inch-thick fully tempered glass
    - o Minimum 1/4-inch-thick laminated glass
    - o Shatter-resistant plastic
- CBC 1134A.6(7)*

## WATER CLOSETS

37. Dimension clear floor space per the following at each accessible water closet:
- ☐ Minimum 48-inches wide
  - Exception:** Minimum 36-inch width acceptable for maximum 24-inch-deep lavatories, cabinets, wing walls, or privacy walls located immediately adjacent to toilet per CBC Figure 11A-9M
  - ☐ Extending minimum 36 inches past front edge of toilet
  - ☐ No door encroachment unless minimum 30-inch by 48-inch maneuvering space provided within bathroom outside door swing

*CBC 1134A.4 and CBC 1134A.7(1)*

38. Dimension 18 inches (absolute) between centerline of water closet fixtures and adjacent side walls or partitions.

**Exception:** Water closets in locations without adjacent walls shall be positioned to allow future installation of grab bar on one side of fixture

*CBC 1134A.7(1)*

39. Detail wall reinforcement complying with the following per CBC Figure 11A-9G(a) at accessible water closet for future installation of grab bars:

- ☐ Located on both sides or one side and rear
- ☐ Rear wall reinforcement per the following:
  - o Minimum 32 inches and maximum 38 inches above floor
  - o Minimum 40-inch length
  - o Minimum 6-inch nominal height
- ☐ Side wall reinforcement per the following:
  - o Minimum 32 inches and maximum 38 inches above floor
  - o Maximum 12 inches from rear wall
  - o Extending minimum 26 inches in front of water closet
  - o Minimum 6-inch nominal height

**Exception:** Water closets in locations without adjacent walls shall be positioned to allow future installation of floor-mounted, fold-away, or similar alternative grab bars

*CBC 1134A.7(2)*

40. Dimension minimum 15-inch height of accessible water closet seats above floor

*CBC 1134A.7(3)*

41. Specify water closet controls complying with the following:
- ☐ Mounted maximum 44 inches above floor
  - ☐ Operable with maximum 5 pounds of force
  - ☐ Operable with one hand and without tight grasping, pinching, or twisting of wrist

*CBC 1134A.7(4)*

## LAVATORIES

42. Dimension location of accessible lavatories to comply with the following:
- ☐ Where forward approach allowed, minimum 18 inches from centerline of fixture to adjacent wall or fixture
  - ☐ Where parallel approach required, minimum 24 inches from centerline of fixture to adjacent wall or fixture
  - ☐ Top of fixture rim maximum 34 inches above floor

*CBC 1134A.8(1)*

43. Dimension clear maneuvering space per the following at each accessible lavatory:

- ☐ Minimum 30 inches by 48 inches centered on lavatory
- ☐ No door encroachment unless minimum 30-inch by 48-inch maneuvering space provided within bathroom outside door swing

*CBC 1134A.4 and CBC 1134A.8(2)*

44. Detail knee clearance beneath accessible lavatories complying with the following:

- ☐ Minimum 30 inches wide
- ☐ Minimum 8 inches deep
- ☐ Minimum 29 inches at front face reducing to minimum 27 inches at point 8 inches back from front edge

*CBC 1134A.8(4)*

45. Detail toe clearance beneath accessible lavatories complying with the following:

- ☐ Minimum 30 inches wide
- ☐ Minimum 9 inches high
- ☐ Minimum 17 inches deep from front edge

*CBC 1134A.8(4)*

46. Specify one of the following configurations to ensure knee and toe clearances provided per items 44 and 45:

- ☐ Space beneath lavatory shall be left clear and unobstructed
- ☐ Any cabinet beneath lavatory shall be removable without specialized tool or knowledge
- ☐ Doors to any cabinet beneath lavatory shall be removable or operable such that required knee and toe clearance provided without obstruction

*CBC 1134A.8(4.3)*

47. Specify the following for knee and toe clearances beneath accessible lavatories:

- ☐ Insulated hot water and drain pipes
- ☐ No sharp or abrasive surfaces
- ☐ Finished floor beneath lavatory shall extend to wall

*CBC 1134A.8(5) and CBC 1134A.8(6)*

48. Specify faucet and mechanism controls complying with the following:

- ☐ Operable with maximum 5 pounds of force
- ☐ Operable with one hand and without tight grasping, pinching, or twisting of wrist
- ☐ Self-closing valves allowed if faucet remains open for minimum 10 seconds

*CBC 1134.8(7)*

49. Specify any mirrors or towel fixtures shall be mounted with bottom edge maximum 40 inches above floor.

*CBC 1134.8(8)*

## LAUNDRY APPLIANCES

50. If washers and dryers are provided in covered multifamily dwelling units, specify at least one each type shall be accessible and front-loading.

**Exception:** Where front-loading washers not provided, management shall provide assistive devices – on request of occupant – for use with top-loading washers

*CBC 1135A.1*

## MISCELLANEOUS

51. Specify controls and operating mechanisms shall comply with the following:

- ☐ Minimum 15 inches and maximum 48 inches high above floor and within reach ranges per accessibility correction list 5A
- ☐ Operable with maximum 5 pounds of force
- ☐ Operable by single effort and without tight grasping, tight pinching, or twisting of the wrist


**Exception:** Appliances – including stoves, dishwashers, range hoods, microwaves – having controls on the appliance

*CBC 1136A.2*


52. Specify any electrical switches or outlets in common-use areas shall be located per the following:

- ☐ Minimum 15 inches from bottom of receptacle/outlet box to finished floor
  - ☐ Maximum 48 inches from top of receptacle/outlet box to finished floor
  - ☐ Within reach ranges per accessibility correction list 5A
- Exception:** Receptacle outlets installed as part of permanent baseboard heaters are exempt from height and reach limits
- Exception:** Required receptacle outlets allowed in floors when adjacent to sliding panels or walls
- Exception:** Baseboard electrical outlets used in relocatable partitions, window walls, or other electrical convenience floor outlets are exempt from minimum height limits


*CBC 1136A.1*




CBC FIGURE 11A-1C(d) – CHANGE IN LEVEL



CBC FIGURE 11A-8I – THRESHOLD



CBC FIGURE 11A-8J – PLATFORM AT SECONDARY EXTERIOR DOOR




CBC FIGURE 11A-8K – RAMP AT SECONDARY EXTERIOR DOOR

**THESE FIGURES ARE FOR ILLUSTRATIVE PURPOSES ONLY.  
THEY ARE NOT INTENDED FOR REPRODUCTION AS PLAN DETAILS.  
IF CONFLICTS EXIST BETWEEN THESE FIGURES AND THE TEXT  
OF THE *CALIFORNIA BUILDING CODE*, THE CODE TEXT SHALL GOVERN.**




CBC FIGURE 11A-9G(a) – WALL REINFORCEMENT FOR FUTURE GRAB BAR INSTALLATION AT ADAPTABLE WATER CLOSET



NOTE: THE AREA OUTLINED IN DASHED LINES REPRESENT LOCATIONS FOR FUTURE INSTALLATION OF GRAB BARS FOR TYP. FIXTURE CONFIGURATIONS


CBC FIGURE 11A-9G(b) – WALL REINFORCEMENT FOR FUTURE GRAB BAR INSTALLATION AT ADAPTABLE BATHTUB




NOTE: THE AREA OUTLINED IN DASHED LINES REPRESENT LOCATION FOR FUTURE INSTALLATION OF GRAB BARS

CBC FIGURE 11A-9G(c) – WALL REINFORCEMENT FOR FUTURE GRAB BAR INSTALLATION AT ADAPTABLE SHOWER

**THESE FIGURES ARE FOR ILLUSTRATIVE PURPOSES ONLY.  
THEY ARE NOT INTENDED FOR REPRODUCTION AS PLAN DETAILS.  
IF CONFLICTS EXIST BETWEEN THESE FIGURES AND THE TEXT  
OF THE CALIFORNIA BUILDING CODE, THE CODE TEXT SHALL GOVERN.**



**CBC FIGURE 11A-9L – SHOWER WITH ADJACENT WATER CLOSET**



**CBC FIGURE 11A-9M – WING WALL OR CABINET AT WATER CLOSET**

**THESE FIGURES ARE FOR ILLUSTRATIVE PURPOSES ONLY.  
THEY ARE NOT INTENDED FOR REPRODUCTION AS PLAN DETAILS.  
IF CONFLICTS EXIST BETWEEN THESE FIGURES AND THE TEXT  
OF THE *CALIFORNIA BUILDING CODE*, THE CODE TEXT SHALL GOVERN.**